

ADS N-12[®] WT IB PIPE SPECIFICATION - AASHTO

Scope

This specification describes 900 to 1500 mm (36- through 60-inch) ADS N-12 WT IB pipe for use in gravity-flow applications.

Pipe Requirements

N-12 WT IB pipe shall have a smooth interior and annular exterior corrugations.

- 36- through 60-inch (900 to 1500 mm) shall be certified by an accredited certification body to meet AASHTO M 294 Type S, and OPSS 1840.
- Manning's "n" value for use in design shall be 0.012.

Joint Performance

Pipe shall be joined with the N-12 WT IB joint meeting the requirements of AASHTO M294. It shall be watertight according to the requirements of ASTM D3212. Gaskets shall be made of polyisoprene meeting the requirements of ASTM F477. Gaskets shall be installed by the pipe manufacturer and covered with a removable, protective wrap to ensure the gasket is free from debris. A joint lubricant available from the manufacturer shall be used on the gasket and bell during assembly. It shall have a reinforced bell with a bell tolerance device. The bell tolerance device shall be installed by the manufacturer.

Fittings

Fittings shall conform to AASHTO M294. Bell and spigot connections shall utilize a spun-on or welded bell and valley or saddle gasket meeting the watertight joint performance requirements of AASHTO.

Field Pipe and Joint Performance

To assure watertightness, field performance verification may be accomplished by testing in accordance with ASTM F2487. Appropriate safety precautions must be used when field-testing any pipe material. Contact the manufacturer for recommended leakage rates.

Material Properties

Virgin material for pipe and fitting production shall be high-density polyethylene conforming with the minimum requirements of cell classification 435400C, as defined and described in the latest version of ASTM D3350, except that carbon black content should not exceed 4%. The virgin pipe material shall comply with the notched constant ligament-stress (NCLS) test as specified in Section 9.5 of AASHTO M294.

Installation

Installation shall be in accordance with CSA B182.11, ASTM D2321 and ADS's published installation guidelines, with the exception that minimum cover in trafficked areas for 900 to 1200 mm (36- through 48-inch) diameters shall be 0.3 m (one foot) and for 1500 mm (60-inch) diameters, the minimum cover shall be 0.6 m (2 ft.) in single run applications. Contact your local ADS representative or visit our website at www.ads-pipe.com for a copy of the latest installation guidelines.

Pipe Dimensions

	Nominal Diameter			
Pipe I.D. in (mm)	900 (36)	1050 (42)	1200 (48)	1500 (60)
Pipe O.D.* in (mm)	1067 (42)	1219 (48)	1372 (54)	1702 (67)

*Pipe O.D. values are provided for reference purposes only, values stated for 900 to 1500 mm are ± 25 mm. Contact a sales representative for exact values.

N-12[®] WT IB JOINT SYSTEM

(Joint configuration & availability subject to change without notice. Product detail may differ slightly from actual product appearance.)

